

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1060791

Product: Selective current relay

Type: RP 1

Rating: In=5-63 A, Un=250 V AC, Ui=400 V AC

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 603125-01/01 of: 25.09.2006

A sample of the product was found to be in conformity with:
ČSN EN 60947-5-1:05 ed.2+1:05, ČSN EN 60947-1:05 ed. 3

The validity of the certificate is limited to: 30.9.2009

6.10.2006

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



603125-01