

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1130068

Product: Residual current operated circuit-breakers

Type: OFE 20, 40

Rating: 230/400 V; 25, 40, 63 A; 50/60 Hz, Inc = 6 kA, I_{res} = 0,03 A; 0,3 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 300297-01/01 of: 30.01.2013

A sample of the product was found to be in conformity with:
EN 61008-1:04 ed.2, EN 61008-2-1:94;

The validity of the certificate is limited to: 29.2.2016

12.2.2013

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



300297-01