

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1130592

Product: Switch

Type: AST

Rating: 125 A, 230/400 V AC, AC 22 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 301258-01/01 of: 17.07.2013

A sample of the product was found to be in conformity with:
ČSN EN 60947-3 ed. 3:10+A1:12
ČSN EN 60947-1 ed. 4:08+A1:11

The validity of the certificate is limited to: 31.7.2016

26.7.2013

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



301258-01