

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1150542

Product: Low-voltage surge protective devices

Type: SVC-255-N-S, SVC-275-1, SVC-275-1-S

Rating: Uc: AC 275 V, Up: ≤ 1,3 kV, In: 30 kA (SVC-255-N-S),
Uc: AC 275 V, Up: ≤ 1,35 kV, In: 20 kA (SVC-275-1, SVC-275-1-S)

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 202594-01/01 of 28.05.2012

A sample of the product was found to be in conformity with:

ČSN EN 61643-11:03+A11:07 cl. 6.1.1, 6.1.2, 7.2.1, 7.2.2, 6.2.1, 6.3, 6.3.1, 6.3.2, 6.3.3, 7.3.1, 7.3.2.1, 7.3.2.2, 7.3.2.2.1, 7.3.2.2.2, 7.3.2.2.3, 7.3.3, 7.7.5, 6.2.7, 7.7.2.1, 7.7.2.2, 7.7.4, 7.7.4.1, 7.7.7.4.2, 7.9.2.1, 7.9.7, 7.9.8, 6.5.1, 7.9.9, 7.9.3, 7.9.3.1, 7.9.3.2, 7.9.5.1, 7.9.4, 6.2.12, 6.2.13

The validity of the certificate is limited to: 31.07.2016

11.08.2015

Prague

Mikulík Jarmil
Deputy Head of Certification Body



Stamp



* C E R / 1 1 5 0 5 4 2 *

502829-01